Exova Warringtonfire Holmesfield Road Warrington WA1 2DS United Kingdom T:+44 (0) 1925 655 116 F:+44 (0) 1925 655 419 E: warrington@exova.com W: www.exova.com

Testing. Advising. Assuring.



Title:

CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1:2007+A1: 2009.

Notified Body No:

0833

Product Name:

"Warmshell Woodfibre"

Report No:

WF 332290

Issue No:

1

Prepared for:

Lime Green Products Ltd Coates Kiln Stretton Road Much Wenlock TF13 6DG

Date:

22nd October 2013



1. Introduction

This classification report defines the classification assigned to "Warmshell Woodfibre", an external wall insulation system, in line with the procedures given in EN 13501-1:2007+A1: 2009.

2. Details of classified product

2.1 General

The product, "Warmshell Woodfibre", an external wall insulation system, is defined as being suitable for construction applications, excluding flooring and linear pipe thermal insulation.

2.2 Product description

The product, "Warmshell Woodfibre", an external wall insulation system, is fully described below and in the test reports provided in support of classification listed in Clause 3.1.

General description		External wall insulation system
Product reference of overall composite		"Warmshell Woodfibre"
Name of manufacturer of overall composite		Lime Green Products Ltd
Thickness of overall composite		200mm (stated by sponsor)
'		200mm (determined by Exova
		Warringtonfire)
Density of overall composite		300kg/m ³ (stated by sponsor)
		301.47kg/m ³ (determined by Exova
		Warringtonfire)
	Generic type	Water-based paint
	Product reference	"2 nd Coat Silicate Mineral Fine
		Waterglass Paint System <5% Organic"
	Name of manufacturer	Beecks
Final coating	Colour reference	"White"
product	Number of coats	One
(test face)	Thickness	<0.5mm
	Application rate	1.4kg/l
	Application method	Brush
	Flame retardant details	See Note 1 below
	Curing process per coat	24 hours air drying
	Generic type	Water-based paint
	Product reference	"1st Coat Silicate Mineral Coarse
		Waterglass Paint System < 5% Organic"
Third coating product	Name of manufacturer	Beecks
	Colour reference	"White"
	Number of coats	One
	Thickness	<0.5mm
	Application rate	1.4kg/l
	Application method	Brush
	Flame retardant details	See Note 1 below
	Curing process per coat	24 hours air drying

Continued on next page



	Generic type	Natural hydraulic lime based render system		
Second coating	Product reference	"Lime Green Finish WP"		
	Name of manufacturer	Lime Green Products		
	Colour reference	"020"		
	Number of coats	One		
product	Thickness	5mm		
p. c.a.a.v	Density	1450kg/m ³		
	Application method	Rendering		
	Curing process per coat	10 days air drying		
	Flame retardant details	See Note 1 below		
	Generic type	Glass fibre mesh		
	Product reference	"Lime Green Glass Fibre Mesh 660"		
	Name of manufacturer	Vitrulan		
Fibre	Colour reference	"Orange"		
reinforcement	Thickness	1-2mm		
	Weight per unit area	146g/m ²		
	Type of weave / cell dimensions	6mm by 6mm		
	Flame retardant details	See Note 1 below		
	Generic type	Natural hydraulic lime based render system		
	Product reference	"Lime Green Prepbond WP"		
	Name of manufacturer	Lime Green		
	Colour reference	See Note 2 below		
First coating	Number of coats	One		
product	Thickness	10mm		
-	Density	1350kg/m ³		
	Application method	Rendering		
	Curing process per coat	3-5 days air drying		
	Flame retardant details	See Note 1 below		
	Generic type	Woodfibre		
	Product reference	"Protect"		
	Name of manufacturer	Steico		
Insulation	Colour reference	See Note 2 below		
	Thickness	180mm		
	Density	250kg/m ³		
	Flame retardant details	See Note 1 below		
Fixing details (insul	ation to plywood)	Ejot STR-H fixings		
	Generic type	Plywood		
	Product reference	"Plywood"		
	Name of manufacturer	See Note 2 below		
Plywood	Thickness	8.50mm (determined by Exova		
		Warringtonfire)		
	Density	580-610kg/m ^{3.}		
	Flame retardant details	See Note 1 below		
Brief description of	manufacturing process	See Note 2 below		

Note 1 - The sponsor of the test has confirmed that no flame retardant additives were utilised in the production of the component. Note 2 - The sponsor was unable to provide this information.



3. Test reports & test results in support of classification

3.1 Test reports

Name of Laboratory	Name of sponsor	Test reports/extended application report Nos.	Test method / extended application rules & date
Exova warringtonfire	Lime Green Products Ltd	WF 332133	EN ISO 11925-2
Exova warringtonfire	Lime Green Products Ltd	WF 332132	EN 13823

3.2 Test results

Test			Results		
method & test number	Parameter	No. tests	Continuous parameter - mean (m)	Compliance parameters	
EN ISO	F_s		Nil	Compliant	
11925-2 (30s exposure - surface)	Flaming droplets/ particles	6	None	Compliant	
EN ISO 11925-2 (30s exposure – edge)	F _s		Nil	Compliant	
	Flaming droplets/ particles	6	None	Compliant	
EN ISO 11925-2	F_s		Nil	Compliant	
(30s exposure - edge at 90 degrees)	Flaming droplets/ particles	6	None	Compliant	
	FIGRA _{0.2MJ}		6.41	Compliant	
EN 13823	FIGRA _{0.4MJ}	3	2.90	Compliant	
	THR _{600s}		0.93	Compliant	
	LFS		None	Compliant	
	SMOGRA		0.00	Compliant	
	TSP _{600s}		14.02	Compliant	



4. Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with clause 8 of EN 13501-1:2007+A1: 2009 and ETAG 004.

4.2 Classification

The product, "Warmshell Woodfibre", an external wall insulation system, in relation to its reaction to fire behaviour is classified:

В

The additional classification in relation to smoke production is:

s1

The additional classification in relation to flaming droplets / particles is:

d0

The format of the reaction to fire classification for construction applications, excluding flooring and linear pipe thermal insulation is:

Fire Behaviour		Smoke Production			Flaming	Droplets
В	-	S	1	,	d	0

i.e. B - s1, d0

Reaction to fire classification: B - s1, d0

4.3 Field of application

This classification is valid for the following end use applications:

i) Construction applications used over any substrate with a density equal to or greater than 680±50kg/m³, having a minimum thickness of 8mm and a fire performance of D-s2, d0 or better.



This classification is also valid for the following product parameters:

Fixing method Insulation product thickness Insulation product density Insulation product type Render thickness

Finishing coat

Reinforcement Product composition

Mechanical fixings 180 or lower 250kg/m³ or lower No variation allowed

Applied thickness or greater

As tested, or with lower organic content

In any colour

Any reinforcement with a lower PCS value No variation allowed apart from specified above

SIGNED

APPROVED

Matthew Dale

Certification Engineer **Technical Department** Janet Murrell

Technical Manager Technical Department on behalf of Exova warringtonfire

This copy has been produced from a .pdf format electronic file that has been provided by Exova Warringtonfire to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Exova Warringtonfire. The pdf copy supplied is the sole authentic version of this document. All pdf versions of this report bear authentic signatures of the responsible Exova Warringtonfire staff.

